



Addressee : **KNAUF INSULATION**  
**95, rue de Maestricht**

**4600 VISE**  
**BELGIQUE**

*For the attention of Mr Etienne DHEUR*

Villeurbanne, 17<sup>th</sup> November, 2008

Person in charge : **Anne TISSOT**

Signature :

A handwritten signature in black ink, appearing to read "A. Tissot", is written over a horizontal line.

**Test Report N° 2814127-2**

**Version : 01**

**TEST OF GLASSWOOL DUCT ACCORDING TO EN 13403**  
**EROSION – AIRTIGHTNESS – RESISTANCE TO PRESSURE**

EQUIPMENT ID: KNAUF INSULATION CLIMACOUSTIC 25 R 0,75

REFERENCE DOCUMENT(S): EN 13403

TESTS MADE BY: Dominique PUGNET

DATE: July 2008

**CENTRE TECHNIQUE DES INDUSTRIES AÉRAULIQUES ET THERMIQUES**

*Mail address :* BP 2042 - 69603 Villeurbanne Cedex - France - Tél. +33 (0)4 72 44 49 00 - Fax. +33 (0)4 72 44 49 49

*Address :* Domaine Scientifique de la Doua - 25, avenue des Arts - 69100 Villeurbanne

*Delivery :* Domaine Scientifique de la Doua - 54, avenue Niels Bohr - 69100 Villeurbanne

*www.cetiat.fr - E. Mail : cetiat.commercial@cetiat.fr - Siret 775 686 967 00024 - Ape 731 Z*

<b>Version</b>	<b>Date</b>	<b>Nature of change</b>	<b>Modified pages</b>
00	21/08/2008	First distributed	
01	17/11/2008	New reference of the glasswool duct	1,4,5,15

**Each new version cancels and replaces the previous one.**

Results of test reports are the exclusive property of the customer and CETIAT prohibits their distribution to third parties without prior written consent.

Any commercial use of the name CETIAT or of test results is subject to CETIAT's prior consent.

This report may be reproduced only in its entirety.

The test reports written by CETIAT are valid only for the equipment provided for the test in the specific conditions under which the test was run.

Information concerning the measurement equipment used for the tests is kept in CETIAT's archives.

The use of these results for designing equipments using this material must take into account manufacturing tolerances and real operating conditions. CETIAT cannot be held liable for such use of these results.

The formulas or codes used to predict either the operation of a device in conditions other than those used in the test or the characteristics of similar devices of different dimensions are based on the state of knowledge at the time the results were delivered and are subject to change. The results obtained through these formulas or codes are given as an indication only.

The original copy of the report is given to the customer and a certified copy is kept at CETIAT.

*C O N T E N T S*

1. INTRODUCTION.....	4
2. SUMMARY OF THE RESULTS .....	5
APPENDIX 1 - Erosion and emission of particles.....	6
APPENDIX 2 - Resistance against pressure test.....	10
APPENDIX 3 - Airtightness test.....	13

## 1. INTRODUCTION

The objective of the tests was to characterise one reference of glasswool duct according to EN 13403 July 2003 "Ventilation for buildings – Non-metallic ducts – Ductwork made from insulation ductboards". Tests were :

- Erosion and Emission of particles (§7.2 of EN 13403)
- Resistance against pressure (§7.3 of EN 13403)
- Air leakage factor and airtightness class (§4.3 of EN 13403, referred to §5.2 of prEN 1507)

The reference of the glasswool duct is KNAUF CLIMACOUSTIC 25 R 0,75.

Summary of the results is in part 2.

Detailed results of erosion and emission of particle tests are in APPENDIX 1 -.

Detailed results of resistance against pressure tests are in APPENDIX 2 -.

Detailed results of air leakage factor and airtightness class tests are in APPENDIX 3 -.

## 2. SUMMARY OF THE RESULTS

<b>EROSION AND EMISSION OF PARTICLES TEST</b>		
Air velocity = 18,8 m/s		
	Requirements	KNAUF INSULATION CLIMACOUSTIC 25 R 0,75
Particles > 0,5 µm	< 60 µg/m <sup>3</sup>	0.036 µg/m <sup>3</sup>
Particles > 5,0 µm	< 4,0 µg/m <sup>3</sup>	0.020 µg/m <sup>3</sup>


The material from the inside surface of the ductwork does not break away, nor flake off and does not show evidence of delamination or erosion.

<b>RESISTANCE AGAINST PRESSURE TEST</b>	
Pressure = 2000 Pa	
KNAUF INSULATION CLIMACOUSTIC 25 R 0,75	
The joining material remained intact. There is no evidence of other damage, which would cause the sample to become unusable.	

<b>AIRTIGHTNESS TEST</b>		
	Pressure	KNAUF INSULATION CLIMACOUSTIC 25 R 0,75
Airtightness class	-756 Pa	C
Airtightness class	1005 Pa	C

## APPENDIX 1 - Erosion and emission of particles

The samples are arranged in an L-shaped assembly. The entire assembly has similar cross-section (300 mm \* 300 mm).



- |                      |                       |
|----------------------|-----------------------|
| 1 : Sucking box      | 5 : Blowing plenum    |
| 2 : Sucking fan      | 7 : Connexion duct    |
| 3 : Control valve    | 8 : Duct to be tested |
| 4 : Absolute filters |                       |

**Figure 1 : Construction for particle emission**

Tests consisted in :

- Purge during 1 h, air velocity = 12 m/s,
- Stop during 15 min,
- Erosion test during 5 h, air velocity = 18,8 m/s.

The particle accounting is made with an optical laser counter with different channels given in Table 1. The counting is not done during the purge.

Channel	Range
1	0,2 – 0,3 µm
2	0,3 – 0,5 µm
3	0,5 – 0,7 µm
4	0,7 – 1,0 µm
5	1,0 – 2,0 µm
6	2,0 – 3,0 µm
7	3,0 – 5,0 µm
8	> 5 µm

**Table 1 : Laser counter range**

The extracted flow rate is of 28,3 l/min.

The average particle concentration is calculated from the extracted air volume and the measurement of the particle's mass using the following formula :

$$C = \frac{M}{Q_v t}$$


Where :

C is the particle concentration in µg/m<sup>3</sup>,


M is the particles' mass in µg,

Q<sub>v</sub> is the extraction flow rate in m<sup>3</sup>/s.


The mass of particles is determined from the number of counted particles and the relative density of the glass (2500 kg/m<sup>3</sup>).



**Figure 2 : View of the test facility**



**Figure 3 : Views of the installation**



**Figure 4 : View of the inside of the sample**

***Detailed results***

Duration of extraction for the optical laser counter : 305 minutes

Extracted flow rate for the optical laser counter : 28,3 l/min = 0,0283 m<sup>3</sup>/min

Extracted flow : 305 × 0,0283 = 8,63 m<sup>3</sup>

Volume of a particle (diameter d) =  $\frac{4}{3} \times \pi \times \left(\frac{d}{2}\right)^3$

Air velocity in the duct : 18,8 m/s

Air temperature : 23.6°C < T < 26.7°C



Range of particles diameter ( $\mu\text{m}$ )	Nb of counted particles	Nb of particles/ $\text{m}^3$	Concentration $\mu\text{g}/\text{m}^3$
0,2 - 0,3	38229	4429	9.06E-05
0,3 - 0,5	17159	1988	1.67E-04
0,5 - 0,7	3780	438	1.24E-04
0,7 - 1,0	3257	377	3.03E-04
1,0 - 2,0	3575	414	1.83E-03
2,0 - 3,0	1585	184	3.76E-03
3,0 - 5,0	1010	117	9.80E-03
> 5,0	1076	125	2.04E-02

**Table 2 : Detailed results of the erosion test**

	Requirements	Test results
Particles > 0,5 $\mu\text{m}$	< 60 $\mu\text{g}/\text{m}^3$	0.036 $\mu\text{g}/\text{m}^3$
Particles > 5,0 $\mu\text{m}$	< 4,0 $\mu\text{g}/\text{m}^3$	0.020 $\mu\text{g}/\text{m}^3$

**Table 3 : Comparison with the requirements**

The material from the inside surface of the ductwork does not break away, flake off and does not show evidence of delamination or erosion.

**The requirements concerning the maximum particle concentration are fulfilled.**

## APPENDIX 2 - Resistance against pressure test

The pressure test determines the fitness for purpose of the ductboard assembly. A test sample is prepared like it can be seen in Figure 5 and Figure 6.

Two typical rectangular section ducts were constructed by KNAUF INSULATION company and assembled with a peripheral joint. The used internal section is 300 mm \* 300 mm.

A pressure tap is sealed on the test sample and connected to a manometer.

An air supply tape is sealed on the test sample to supply specified air pressure.




Figure 5 : View of the test facility

Fan




**Figure 6 : View of the test facility**

The manufacturer's rated pressure is 800 Pa.

This pressure is gradually reached in a time between 45 and 60 s, and is maintained during 1 min. It is then increased to 2000 Pa (2,5 times 800 Pa), and maintained during 1 h.

***Detailed results***





**Figure 7 : Views of the sample after the pressure test**

As it can be seen on Figure 7, the joining material remained intact. There is no evidence of other damage, which would cause the sample to become unusable.

### APPENDIX 3 - Airtightness test


Tests are made following NF EN 1507 July 2006 standard.

The test sample built by KNAUF INSULATION consists of 7 modules of 1,2 m of length and section of 300 mm × 300 mm.

For each sample :

Ductwork surface area (A) =  $7 \times 1,2 \times 4 \times 0,3 = 10,1 \text{ m}^2$

Total joint length (L) =  $6 \times 4 \times 0,3 + 7 \times 1,2 = 15,6 \text{ m}$



**Figure 8 : Diagram of the samples**

CETIAT closed the ends of each sample with metal sheets.

Table 4 shows the airtightness classification defined in the NF EN 1507 standard.

Air tightness class	Air leakage limit $\text{l.s}^{-1}.\text{m}^{-2}$	Static gauge pressure limits (Pa)	
		Negative	Positive
A	$0,027.p_{\text{test}}^{0,65}$	-200	1000
B	$0,009.p_{\text{test}}^{0,65}$	-500	1000
C	$0,003.p_{\text{test}}^{0,65}$	-750	1000

**Table 4 : Definition of the airtightness classes – NF EN 1507**

The maximum negative pressure and positive pressure for the tests are defined by KNAUF INSULATION company :

- The maximum negative pressure is -750 Pa.
- The maximum positive pressure is 1000 Pa.

### Detailed results

Atmospheric pressure: 99500 Pa


Air temperature: 22.6 to 23.2°C

#### Negative pressure


Pressure Pa	Airflow rate m3/h	Airflow rate at 20°C and 101325 Pa		Leakage rate	
		m3/h	l/s	m3/h/m2	l/s/m2
-201	0.6	0.6	0.2	0.06	0.02
-306	0.9	0.9	0.2	0.09	0.02
-401	1.1	1.0	0.3	0.11	0.03
-503	1.2	1.2	0.3	0.12	0.03
-601	1.3	1.2	0.3	0.13	0.03
-756	2.2	2.1	0.6	0.22	0.06

#### Positive pressure


Pressure Pa	Airflow rate m3/h	Airflow rate at 20°C and 101325 Pa		Leakage rate	
		m3/h	l/s	m3/h/m2	l/s/m2
203	0.2	0.2	0.0	0.02	0.00
401	0.4	0.4	0.1	0.04	0.01
602	0.7	0.7	0.2	0.07	0.02
806	0.9	0.9	0.2	0.09	0.02
1005	1.4	1.3	0.4	0.13	0.04



**Figure 9 : Leakage flow rate according to the negative pressure**



**Figure 10 : Leakage flow rate according to the positive pressure**



**Figure 11 : View of the test facility**